

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-0328:160 Page 1 of 1

**CATEGORY:** Fire Alarm Device for the Hearing Impaired

**LISTEE:** Potter, 2081 Craig Road, St. Louis MO 63146  
Contact: Brad Serangeli (314) 878-4321

**DESIGN:** Model OS-2475R synchronous and non-synchronous strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Candela: 75cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as strobe lights for the hearing impaired when used in conjunction with separately listed compatible fire alarm control units. For indoor use, wall mount only.

**XLF:** 7125-0587:111

03-13-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager